



0401

CERTIFICATE OF CALIBRATION

Ricardo Energy & Environment, 18 Blythswood Square, Glasgow, G2 4BG

Telephone 01235 753642

Authorised Signatories: D Hector
S Stratton✓

Signed:  Date of Issue: 28th July 2017

Certificate Number: 3766

Page 1 of 3

Customer Name and Address: Scottish Government
Water, Air, Soils and Flooding Division
Environmental Quality Directorate
Scottish Government
Victoria Quay
Edinburgh
EH6 6QQ

Description: Calibration factors for North Lanarkshire Council's Chapelhall, Croy, Coatbridge Whifflet, Kirkshaws, Moodiesburn, Motherwell and Shawhead Coatbridge air monitoring station's.

| Site / Date Test Carried Out | Species | Analyser Serial No. | Zero Response ¹ | Uncertainties ppb | Calibration Factor ² | Uncertainties % | Converter eff. (%) ³ |
|---|-----------------|---------------------|----------------------------|-------------------|---------------------------------|------------------|---------------------------------|
| Chapelhall 1 st March 2017 | NO _x | AT4DAK5Y | -2.7 | 2.5 | 1.0077 | 3.5 | 95.6 |
| | NO | | -3.1 | 2.5 | 1.0149 | 3.5 | |
| Croy 28 th February 2017 | NO _x | AYKTCJU8 | 0.1 | 2.5 | 0.9963 | 3.5 | 99.6 |
| | NO | 5776290409 | 0.4 | 2.5 | 1.0307 | 3.5 | |
| | SO ₂ | | 0.9 | Unable to report | 1.5897 | Unable to report | |
| | O ₃ | OO4003 | 0.2 | 0.2 | 1.0297 | 3.5 | |
| Kirkshaws 2 nd March 2017 | NO _x | P8GT9WHE | 5.5 | 2.7 | 1.3943 | 3.5 | 99.6 |
| | NO | | 1.7 | 2.8 | 1.4905 | 3.5 | |
| Moodiesburn 1 st March 2017 | NO _x | 7NLHD0L8 | 0.6 | 2.5 | 0.9557 | 3.5 | 99.3 |
| | NO | | 0.4 | 2.6 | 0.9782 | 3.5 | |

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2 providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory. Ricardo Energy & Environment is a trading name of Ricardo-AEA Ltd.

Ricardo Energy & Environment

Head Office
Gemini Building,
Fermi Avenue,
Harwell,
Oxon
OX11 0QR

Tel: +44 (0)1235 753 000

Registered office

Shoreham Technical Centre
Shoreham-by-Sea
West Sussex
BN43 5FG

Registered in England No.

08229264

VAT Registration No.

GB 212 8365 24

| Site / Date Test Carried Out | Species | Analyser Serial No. | Zero Response ¹ | Uncertainties ppb | Calibration Factor ² | Uncertainties % | Converter eff. (%) ³ |
|---|-----------------|---------------------|----------------------------|-------------------|---------------------------------|-----------------|---------------------------------|
| Shawhead Coatbridge 2 nd March 2017 | NO _x | 7NHSKHBC | -1.8 | 2.5 | 0.9731 | 3.5 | 99.3 |
| | NO | | -1.1 | 2.5 | 0.9873 | 3.5 | |

| Site / Date Test Carried Out | Species | Analyser Serial No. | Parameter | Specified Value | Measured Value | Deviation % | Uncertainty % |
|--|--------------------------|---------------------|-----------------------------|-----------------|----------------|-------------|---------------|
| Chapelhall 1 st March 2017 | TEOM PM ₁₀ | 25426 | Main Flow ⁴ | 3.00 | 3.02 | 0.5 | 2.25 |
| | | | Aux Flow ⁴ | 13.67 | | | |
| | | | Total Flow | 16.67 | 16.92 | 1.5 | 2.25 |
| | | | k ₀ ⁵ | 10372 | 10405 | 0.3 | 1.00 |

| | | | | | | | |
|--|--------------------------|-------|-----------------------------|-------|--------------|------|------|
| Croy 28 th February 2017 | TEOM PM ₁₀ | 21769 | Main Flow ⁴ | 3.00 | 3.11 | 3.7 | 2.25 |
| | | | Aux Flow ⁴ | 13.68 | 14.23 | 4.0 | 2.25 |
| | | | Total Flow | 16.67 | 17.34 | 4.0 | 2.25 |
| | | | k ₀ ⁵ | 14864 | 14658 | -1.4 | 1.00 |

| | | | | | | | |
|---|--------------------------|-------|-----------------------------|-------|--------------|-----|------|
| Coatbridge Whifflet 2 nd March 2017 | TEOM PM ₁₀ | 25385 | Main Flow ⁴ | 3.00 | 3.11 | 3.6 | 2.25 |
| | | | Aux Flow ⁴ | 13.69 | 14.06 | 2.7 | 2.25 |
| | | | Total Flow | 16.67 | 17.17 | 3.0 | 2.25 |
| | | | k ₀ ⁵ | 12763 | 12978 | 1.7 | 1.00 |

| | | | | | | | |
|--|--------------------------|-------|-----------------------------|-------|-------|------|------|
| Motherwell 1 st March 2017 | TEOM PM ₁₀ | 24903 | Main Flow ⁴ | 3.00 | 3.11 | 3.7 | 2.25 |
| | | | Aux Flow ⁴ | 13.69 | 14.90 | 8.8 | 2.25 |
| | | | Total Flow | 16.67 | 18.01 | 8.0 | 2.25 |
| | | | k ₀ ⁵ | 13124 | 12913 | -1.6 | 1.00 |

| Site / Date Test Carried Out | Species | Analyser Serial No. | Parameter | Specified Value | Measured Value | Deviation % | Uncertainty % |
|---|----------|---------------------|-------------------------|-----------------|----------------|-------------|---------------|
| Kirkshaws 2 nd March 2017 | BAM PM10 | P15543 | Total Flow ⁴ | 16.67 | 16.28 | -2.3 | 2.25 |

| | | | | | | | |
|---|----------|-------|-------------------------|-------|-------|------|------|
| Moodiesburn 1 st March 2017 | BAM PM10 | H4552 | Total Flow ⁴ | 16.67 | 15.58 | -6.5 | 2.25 |
|---|----------|-------|-------------------------|-------|-------|------|------|

| | | | | | | | |
|---|----------|-------|-------------------------|-------|-------|-------|------|
| Shawhead Coatbridge 2 nd March 2017 | BAM PM10 | J2657 | Total Flow ⁴ | 16.67 | 11.30 | -32.2 | 2.25 |
|---|----------|-------|-------------------------|-------|-------|-------|------|

The gaseous ambient analysers listed above have been tested for zero response, calibration factor, linearity and converter efficiency (NO_x analysers only) by documented methods. The factors have been calculated using certified gas standards. The particulate analysers listed above have been tested for sample flow rates and k₀ (where appropriate) by documented methods. Note that the test results are valid on the day of test only, as analyser drift over time cannot be quantified. All results for gaseous species are given in ppb (parts per billion) mole fractions or ppm (parts per million) mole fractions.

¹The zero response is the zero reading on the data logging system of the analyser when audit zero gas was introduced to the analysers under test.

²The calibration factor is the multiplying factor required to scale the reading on the data logging system of the analyser into reported concentration units (ppb for NO, NO_x, SO₂, O₃ and ppm for CO. Where 1 ppm = 1000 ppb). It should be used in conjunction with the zero response. A corrected concentration is calculated using the following equation:

$$\text{Concentration} = F (\text{Output} - \text{Zero Response})$$

Where F = Calibration Factor provided on this certificate
Output = Reading on the data logging system of the analyser
Zero Response = Zero Response provided on this certificate

³Converter eff. is the measured efficiency of the NO₂ to NO converter within the oxides of nitrogen analyser under test.

⁴The measured main flow rate (where applicable) is the flow rate through the sensor unit of the TEOM particulate analyser under test. The measured aux flow rate (where applicable) is the flow rate through the bypass tubing of the TEOM particulate analyser under test. The measured total flow rate is the total flow rate through the particulate analyser under test. Units of flow are l.min⁻¹. Where flow rates are highlighted in bold, it indicates that measurements were not made at the analyser sample inlet. These measurements therefore may not accurately reflect analyser performance in normal operation.

⁵The calculated k₀ value (TEOM analysers only) is the calculated k₀ spring constant based on tests undertaken with filters of known weight. The % deviation indicates the closeness of the calculated result to the manufacturer's specified k₀ value.

The calibration results shaded are those that fall out with our scope of accreditation, all other results on this certificate are not UKAS accredited, but have been included for completeness.